

BTMA Daily Report

Friday, November 20, 2009
Weather: 38 to 58 F Cloudy

Contract No 2 Collection and Conveyance Lines – Village of Bethel

Marks Contracting: None

No Work

Contract No 3 Pump Stations – Village of Bethel

Marks Contracting: None

No Work

Contract No 4 Waste Water Treatment Plant – Village of Bethel

Marks Contracting: None

No Work

Contract No 5 Waste Water Treatment Plant – Village of Frystown

Marks Contracting: None

No Work

Contract No 6 Mechanical (HVAC)

Shannon Smith: None

No Work

Contract No 7 Plumbing

TMI Commercial: 7:00 am to 11:30 am

Frystown WWTP

TMI Commercial was on site to receive delivery of material for the Frystown WWTP.

Contract No 8 Electrical

JB Electric: 7:00 am to 3:00 pm

Frystown WWTP

JB Electric completed installation of the fluorescent lights in the blower room. JB Electric pulled wires from the automatic transfer switch to the main distribution panel.

Lateral Hookups

The following residents from the Village of Frystown and Bethel connected to the new sewage system:

Name	Address	System	Remarks
Ronald & Darlene Webber	31 School Rd.	Bethel-82	
Walter & Abby Tyson	8301 Lancaster Ave.	Bethel-83	