
BTMA Daily Report

Monday, November 23, 2009

Weather: 37 to 52 F Rain

Contract No 2 Collection and Conveyance Lines – Village of Bethel

Marks Contracting: None

No Work

Contract No 3 Pump Stations – Village of Bethel

Marks Contracting: None

No Work

Contract No 4 Waste Water Treatment Plant – Village of Bethel

Marks Contracting: None

No Work

Contract No 5 Waste Water Treatment Plant – Village of Frystown

Marks Contracting: 7:00 am to 1:00 pm

Promax Fence (sub-contractor): 7:00 am to 3:00 pm

Security Fencing

Promax began the installation of the vinyl coated chain link fence surrounding the site. Drilled 20" x 36" holes for the fence posts on the west and south sides of the site.

Contract No 6 Mechanical (HVAC)

Shannon Smith: None

No Work

Contract No 7 Plumbing

TMI Commercial: None

No Work

Contract No 8 Electrical

JB Electric: 7:00 am to 3:00 pm

Frystown WWTP

JB Electric pulled wires from the MDP to the transformer and began making necessary terminations.

Lateral Hookups

The following residents from the Village of Frystown and Bethel connected to the new sewage system:

Name	Address	System	Remarks
Carl & Dorinda Kauffman	42 Legion Dr.	Bethel-85	
Brian & Marlene Eisenhour	8455 Lancaster Ave.	Bethel-86	
Allen & Lois Keeney	9760 Old Rt. 22	Bethel-87	