

## BTMA Daily Report

Friday, February 5, 2010

Weather: 25 to 35 Wintery Mix

---

### Contract No 2 Collection and Conveyance Lines – Village of Bethel

Marks Contracting: None

**No Work**

---

### Contract No 3 Pump Stations – Village of Bethel

Marks Contracting: None

Envirep: (Sub-Contractor) 8:00am-12:00pm

**Old Route 22**

Envirep completed the 6 month recertification on the pumps.

**Lancaster Ave**

Envirep completed the 6 month recertification on the pumps.

---

### Contract No 4 Waste Water Treatment Plant – Village of Bethel

Marks Contracting: None

**No Work**

---

### Contract No 5 Waste Water Treatment Plant – Village of Frystown

Marks Contracting: None

**No Work**

---

## Contract No 6 Mechanical (HVAC)

Shannon Smith: None

**No Work**

---

## Contract No 7 Plumbing

TMI Commercial: None

**No Work**

---

## Contract No 8 Electrical

JB Electric: 7:00 am to 3:00 pm

### **Bethel WWTP**

JB Electric completed the installation of the heat trace on the WAS/RAS pipe ball valves in the clarifying tanks. JB Electric also completed various punch list items.

---

## Lateral Hookups

The following residents from the Village of Frystown and Bethel connected to the new sewage system:

Name	Address	System	Remarks
None			